

CERTIFICATE OF CONSTANCY OF PERFORMANCE

0751-CPR.2-039.0-01

In compliance with Regulation (EU) 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

Factory made mineral wool (MW) products for thermal insulation of building equipment and industrial installations
(details cf. annex)

Placed on the market under the name or trade mark of

ROCKWOOL Polska Sp. z o. o.

Ul. Kwiatowa 14
66-131 Cigacice
Poland

and produced in the manufacturing plant

ROCKWOOL, a.s.

Cihelní 769, Skřečůň Moravskoslezský kraj
73531 Bohumín
Czech Republic

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard

EN 14303:2009+A1:2013

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

constancy of performance of the construction product.

This certificate was first issued on 04.07.2014 and will remain valid (but no longer than 18.03.2026) as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

Gräfelfing, 18.03.2025



Certification Body

Ralph Alberti
Ralph Alberti

A publication of extracts to the Certificate of Constancy of Performance and its annex requires the prior written approval of FIW München. Certification body accredited by DAkkS according to DIN EN ISO/IEC 17065:2013. The accreditation is only valid for the scope of accreditation listed in the annex to the certificate D-ZE-14116-01-00. This certificate replaces the issue of 23.09.2024.

Forschungsinstitut für Wärmeschutz e.V. München
Lochhamer Schlag 4 · 82166 Gräfelfing · Germany

Telephone: +49 (0)89 85800-0 · Telefax: +49 (0)89 85800-40
info@fiw-muenchen.de · www.fiw-muenchen.de

Factory:

ROCKWOOL, a.s., Cihelní 769, Skřečň Moravskoslezský kraj, 73531 Bohumín, Czech Republik

Construction product(s):

Factory made mineral wool (MW) products for thermal insulation of building equipment and industrial installations according to EN 14303:2009+A1:2013

Intended use:

Thermal insulation products for building equipment and industrial installations

Reaction to fire:

Products for which a clearly identifiable stage in the production process results in an improvement in the reaction to fire classification by limiting of organic material.

Detailed information on the insulation products can be found in the classification reports

Products	Form	Lamination	Remark	Fire class	Range	Classification report
HEATROCK PS	Pipe section	Reinforced aluminium foil	Production line: BOH2/CIR3	A2L-s1,d0	Density: 90 kg/m ³ to 110 kg/m ³ Wall thickness: 20 mm to 60 mm Max. organic content: 3,8 mass% and 4,2 kg/m ³	230009473-3
HEATROCK PS	Pipe section	Reinforced aluminium foil	Production line: BOH2/CIR4	A2L-s1,d0	Density ≤ 100 kg/m ³ Wall thickness ≤ 50 mm Max. organic content: 3,8 mass% and 4,2 kg/m ³	PK-20-197
HEATROCK PS	Pipe section	Reinforced aluminium foil	Production line: BOH2/CIR5	A2L-s1,d0	Density ≤ 100 kg/m ³ Wall thickness ≤ 50 mm Max. organic content: 3,8 mass% and 4,2 kg/m ³	PK-23-157

Products	Form	Lamination	Remark	Fire class	Range	Classification report
Rockwool 800	Pipe section	Reinforced aluminium foil	Production line: BOH2 & PSM 1,2,3	A2L-s1,d0	Density: 90 - 150 kg/m ³ Wall thickness: ≥ 20 mm Max. organic content: 3,0 mass% and 4,2 kg/m ³	230010154-4 PK-25-022
Rockwool 800	Pipe section	Reinforced aluminium foil	Production line: BOH2 & PSM 1,2,3	A2-s1,d0	Density: 90 - 140 kg/m ³ Wall thickness: 20 mm to 120 mm Outside diameter: > 300 mm Max. organic content: 3,0 mass% and 4,2 kg/m ³	230010154-4 PK-25-023
Rockwool 800 Multi	Pipe section	Reinforced aluminium foil	Production line: BOH2/CIR3/CIR 4	A2L-s1,d0	Density ≤ 100 kg/m ³ Wall thickness ≤ 60 mm Max. organic content: 3,8 mass% and 4,2 kg/m ³	PK-22-030
Tecalit PS	Pipe section	Reinforced aluminium foil	Production line: BOH2/CIR3	A2L-s1,d0	Density: 90 kg/m ³ to 110 kg/m ³ Wall thickness: 20 mm to 60 mm Max. organic content: 3,8 mass% and 4,2 kg/m ³	230011021-3
Tecalit PS	Pipe section	Reinforced aluminium foil	Production line: BOH2/CIR4	A2L-s1,d0	Density: ≤ 100 kg/m ³ Wall thickness: ≤ 30 mm Max. organic content: 3,8 mass% and 4,2 kg/m ³	PK-24-090
Tecalit PS	Pipe section	Reinforced aluminium foil	Production line: BOH2/CIR5	A2L-s1,d0	Density: ≤ 100 kg/m ³ Wall thickness: ≤ 30 mm Max. organic content: 3,8 mass% and 4,2 kg/m ³	PK-24-089

Products	Form	Lamination	Remark	Fire class	Range	Classification report
HEATROCK PS	Pipe section	Reinforced aluminium foil	Production line: BOH2 & PSM 1,2,3	A2L-s1,d0	Density: 90 - 150 kg/m ³ Wall thickness: ≥ 20 mm Max. organic content: 3,0 mass% and 4,2 kg/m ³	230010154-4 PK-25-022
HEATROCK PS	Pipe section	Reinforced aluminium foil	Production line: BOH2 & PSM 1,2,3	A2-s1,d0	Density: 90 - 140 kg/m ³ Wall thickness: 20 mm to 120 mm Outside diameter: > 300 mm Max. organic content: 3,0 mass% and 4,2 kg/m ³	230010154-4 PK-25-023

Gräfelting: 18.03.2025


 Certification body
Ralph Albrecht
 Ralph Albrecht